

# TEST REPORT

**Intertek**

**ETL SEMKO**

**REPORT NUMBER: 3133961-01**  
**ORIGINAL ISSUE DATE: OCTOBER 16, 2007**

**EVALUATION CENTER**  
Intertek Testing Services NA Inc.  
8431 Murphy Drive  
Middleton, WI 53562

**RENDERED TO**

**INTERWRAP INC.**  
**32923 MISSIONS WAY**  
**MISSION, B.C.**  
**V2V 6E4**  
**CANADA**

**PRODUCT EVALUATED: PSU 30 Underlayment for acceptance to ICC ES AC 207 for Polypropylene Roof Underlayments.**  
**EVALUATION PROPERTY: Fire penetration resistance per ASTM E 108 Burning Brand and Intermittent Flame criteria.**

**Report of Testing for Interwrap Inc. PSU 30 Underlayment for compliance with the applicable requirements of: "Acceptance Criteria for Roof Underlayments" ICC-ES AC207 (2003) referencing ASTM E108 (2004) "Standard Test Methods for Fire Tests of Roof Coverings".**

*This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.*

## 6 Conclusion

The results per ICC-ES AC207 (2003) "Acceptance Criteria for Polypropylene Roof Underlayments" section 4.8, ASTM E108 (2004) "Standard Test Methods for Fire Tests of Roof Coverings", UL 790 (1997), and UBC 15-2 (1997) are summarized in the table below.

Deck#	Deck Type	Deck Slope	Deck material	Underlayment	Result
1	IF Class 'A'	5:12	3/8" AC plywood	PSU 30 self adhering	Pass Class 'A'
2	IF Class 'A'	5:12	3/8" AC plywood	PSU 30 self adhering	Pass Class 'A'
4	BB Class 'A'	5:12	3/8" AC plywood	PSU 30 self adhering	Pass Class 'A'
5	BB Class 'A'	5:12	3/8" AC plywood	PSU 30 self adhering	Pass Class 'A'
6	BB Class 'A'	5:12	3/8" AC plywood	PSU 30 self adhering	Pass Class 'A'
7	BB Class 'A'	5:12	3/8" AC plywood	PSU 30 self adhering	Pass Class 'A'

The InterWrap Inc. self adhering PSU 30 Underlayment roofing material, as described herein, complied with the acceptance criteria of ICC-ES AC207 (2003) "Acceptance Criteria for Polypropylene Roof Underlayments" section 4.8, referencing ASTM E108 (2004) "Standard Test Methods for Fire Tests of Roof Coverings"

This report does not automatically imply product certification. Products must be under a certification program and bear the Warnock Hersey registered certification mark to demonstrate compliance.

Reported by:   
Greg Allen  
Lead Technician -Fire  
Intertek Building Products

Reviewed by:   
Kent Kelsey  
Project Manager -Fire  
Intertek Building Products